
 Fire Extinguisher (2)



Spacing of Tables - In occupancies having rectangular conference or banquet type tables, such tables shall be placed not less than 54" apart and not less than 36" from walls